



# TEST CERTIFICATE

## TEST CERTIFICATE

According to the Guideline on the Hygienic Assessment of Organic Materials in Contact with Drinking Water (KTW Guideline, 07 March 2016)

NX Filtration  
Institutenweg 35  
7521 PH Enschede  
The Netherlands

Test Certificate no.: K100659  
Validity: 01.04.2019 till 01.04.2024  
Product: Membrane Filtration Elements  
Tradename: MF500, MF100, UF250, UF75, UF10, dNF80, dNF40 and dNF20 hollow fiber membranes in WMC, BMC or WED module elements

The products Membrane Filtration Elements have been tested in accordance with the Guideline on the Hygienic Assessment of organic materials in contact with drinking water of the German Environment Agency and has passed the test (according to test report 031800022-0194) for the following temperature range:

Element type	Cold water (23 °C)	Warm water (60 °C)	Hot water (85 °C)
MF500	passed	---	---
MF100	passed	---	---
UF250	passed	---	---
UF75	passed	---	---
UF10	passed	---	---
dNF80	passed	---	---
dNF40	passed	---	---
dNF20	passed	---	---

Compliance to the requirements for enhancement of microbial growth has not been tested.

This test certificate is valid from the date of issue and, given that the conditions and requirements remain unaltered, expires by 01-04-2024. Upon request the validity may be extended up to another 5-year term provided that the specifications of the KTW Guideline are met.

Dirkjan van den Berg / i.V. Kerstin Schubert  
Kiwa

The test results and assessments refer exclusively to the examined test specimens and all applicable statutory regulations. The validity of this document expires in case of modifications in the composition of the material or the processing conditions. This present document may only be published and reproduced unabridged and unaltered.

Kiwa GmbH  
Am Weidenbruch 22  
18196 Kessin (Rostock)

Tel. +49 (0)38208 637 0  
Fax +49 (0)38208 637 28  
www.kiwa.de

